



Safety & Buildings Division
201 West Washington Avenue
P.O. Box 2658
Madison, WI 53701-2658

Evaluation #

200501-H

Wisconsin Building Product Evaluation

Direct Vent Gas Furnace: The GM, AM, DM, GC, AC, & DC product lines consist of a series of furnaces using a tubular style heat exchanger. Units are designed for **indoor residential** applications. The GMT are non-condensing furnaces and may be installed in the "Up-Flow" or "Horizontal" position.

Manufacturer: Goodman Manufacturing Corporation
1440 Green Grass
Houston, Texas 77008

Approved Product(s): Trade Name: **Goodman and Amana**

<u>Amana</u>	<u>Amana Distinctions</u>	<u>Goodman</u>
AMS90453BX*	DMS90453BX*	GMS90453BX*
0703BX*	0703BX*	0703BX*
0704CX*	0704CX*	0704DX*
0904CX*	0904CX*	0904DX*
0905DX*	0905DX*	0905DX*
1155DX*	1155DX*	1155DX*
ACS90453BX*	DCS90453BX*	GCS90453BX*
0703BX*	0703BX*	0703BX*
0704CX*	0704CX*	0704CX*
0904CX*	0904CX*	0904DX*
0905DX*	0905DX*	0905DX*
1155DX*	1155DX*	1155DX*
AMV90453BX*		GMV90453BX*
0704CX*		0704CX*
0905DX*		0905DX*
1155DX*		1155DX*
ACV90704CX*		GCV90704CX*
0905DX*		0905DX*

*Denotes minor revision change (initially released as "A")

SCOPE OF EVALUATION: "This evaluation was based on receipt of a signed statement from the testing agency that the product passed the Wisconsin code required test(s) see test section. No other department evaluation was conducted."

TESTS: ANSI Z21.47 the Standard for Direct Vent Central Furnaces, tested and certified by ETL.

LIMITATIONS OF APPROVAL: The furnaces shall be installed in accordance with their listing and the manufacturer's recommendations.

Architectural and mechanical plans and specifications shall be submitted in accordance with the requirements outlined in **s. Comm 20.09(4)**.

The GM, AM, DM, GC, AC, & DC SERIES DOES NOT MEET THE DEFINITION OF A DIRECT VENT SEALED COMBUSTION APPLIANCE AND ARE NOT APPROVED AS SUCH.

This approval will be valid through December 31, 2010, unless manufacturing modifications are made to the product or a re-examination is deemed necessary by the department.

The Wisconsin Building Products Evaluation number must be provided when plans that include this product are submitted for review.

DISCLAIMER: The department is in no way endorsing or advertising this product. This approval addresses only the specified applications for the product and does not waive any code requirement not specified in this document.

Revision Date:

Approval Date: March 23, 2005 By: _____

Lee E. Finley, Jr.
Product/Material &
Building Plan Review
Integrated Services Bureau

200501-H.doc